



- NOTES:**
- 1 RELOCATE EXISTING SPRINKLER PIPING AS REQUIRED AND PROVIDE NEW SPRINKLERS TO NEW CEILING GRID IN DASHED AREA TO PROVIDE SPRINKLER COVERAGE PER NFPA 13 FOR LIGHT HAZARD CLASSIFICATION. WHERE NOT IN CONFLICT WITH NEW HVAC WORK, EXISTING PIPING MAY BE REUSED.
  - 2 OFFSET NEW AND EXISTING PIPING AROUND DUCTS, TERMINAL UNITS, ELECTRICAL DEVICES, ETC. TO PROVIDE CLEARANCE.
  - 3 EXISTING SPRINKLERED AREA TO REMAIN.

CAD#29077 JAN-26-17 L&B PROJ. #6657

**1 PARTIAL FIRST FLOOR - FIRE PROTECTION PLAN**

