

OWASSO PUBLIC SCHOOLS

Morrow Elementary

Owner:
Independent School District No. 111
Tulsa County
Owasso, Oklahoma

Architect: The Stacy Group
Project Number: 1507

03.06.2018



addendum number: Three (3)
date: 04.4.2018
project: OWASSO PUBLIC SCHOOLS
MORROW ELEMENTARY
OWASSO, OK
project number: 1507
architect: The Stacy Group
8091 n. Owasso Expressway
Owasso, Oklahoma 74055
Ph: (918) 272.2622
Fx: (918) 272.2633

To: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated **March 6, 2018**, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

Clarifications:

A3-1 Pre-Manufactured Aluminum Canopy: Referenced on A150, A403 and A504 to be 12' wide by 3'-6" deep

Pre-qualifications:

A3-2 **Section 072762 Fluid Applied Membrane Air Barriers:** Manufacturer listed below is approved in name only and must still meet all requirements as listed in the specification in order to bid and supply products for this project specifications:
Soprema: Sopraseal LM 203

A3-3 **Section 074243 Composite Wall Panels:** Manufacturer listed below is approved in name only and must still meet all requirements as listed in the specification in order to bid and supply products for this project specifications:
Northclad Rainscreen Solutions: Northclad ACM Composite Panel System

A3-4 **Section 074500 Thermoplastic Membrane Roofing:** Manufacturer listed below is approved in name only and must still meet all requirements as listed in the specification in order to bid and supply products for this project specifications:
Soprema: Sentinel P150

A3-5 **Section 075216 Modified Bituminous Membrane Roofing:** Manufacturer listed below is approved in name only and must still meet all requirements as listed in the specification in order to bid and supply products for this project specifications:
Soprema: Elastophene Sanded 2.2 base Ply w/ Elastophene LS GR cap sheet, Sopralast 50 TV Alu flashing

Specifications:

A3-6 **Section 282300 VIDEO SURVEILLANCE AND ACCESS CONTROL:** Add cameras as follows;
interior/exterior camera shall be Bosch NDE-4502-AL FLEXIDOME IP 4000i 2MP 3-10mm AVF VANDAL IP66 IR
Add Recorder as follows: S2NetVR125 w/2 8TB Drives - / RAID=5 / Storage=9001.84 GB /
Bandwidth=102.65 Mbits / Clients Streams=4

Drawings: None

END OF ADDENDUM